

Control Valves (4) new full arc admission, via valve chest
combine reheat stop and intercept valves (2)

Condensers

3 Variable Pressure Condenser Hoods

Feedwater Heaters

Dual string of 3 high pressure feedwater heaters (8A/8B, 7A/7B, & 6A/6B)

LP FW Heater String (deaerator, 4, 3, 2, 1A/1B/1C, DC)

Pumps/BFPT

2 Boiler Feed Pump

2 Boiler Feed Pump Turbines

3 Booster Boiler Feed Pumps

3 Condensate Pumps